

SIGNAGE & SIGNAGE BACKGROUND
FOOD COURT

PART 1 - GENERAL

1.1 DESCRIPTION OF WORK

- A. Includes the following:
1. Food Court signage and background.

1.2 QUALITY ASSURANCE

- A. Field Measurement: Field measure transom and bulkhead height prior to preparation of shop drawings and fabrication to ensure proper fitting of the work. Indicate field measurements on final shop drawings.
- B. Signage shall comply with Appendix H "Signs" of the 2003 IBC. Illuminated signage shall also comply with the ICC Electrical Code.

1.3 SUBMITTALS

- A. Shop Drawings: Submit shop drawings showing background, attachment to ceiling structure or soffit, signage material type size A power requirements. Signage attachment to perforated aluminum background.

PART 2 - PRODUCTS

2.1 SIGNAGE BACKGROUND

- A. Provide the following signage background:

1. Food Court

a. Sizes:

Option A - 24"H x 120"W

Option B - 24"H x 192"W

b. Material:

.063 Ga. Aluminum with 1/2" perforations on 11/16 staggered centers

c. Finish:

All materials to have automotive enamel metallic silver finish (punched backgrounds, trim, standoffs, sleeves)

d. Trim:

1 1/2" x 1 1/2" x 1/8" thk. Angle aluminum MIG welded to punched surface with hidden welds

e. Weight Limitations:

Any signs installed to surface of mounting grid not to exceed 2.5 lbs. per sq. ft or 50 lbs. for 24" x 120"

f. Hardware/Installation:

Option A - 5/16" toggle bolts mounted through steel interior studs

Option B - (Hanging) 3/8" all thread w/ matching sleeve to cover threads, attached above through existing framework.

g. Standoffs:

1" x 1" x 1/8" thk. angle aluminum, 6" in length to accommodate a 2" x 8" "wire way" for illuminated options (any longer could compromise weight restrictions)

2.2 SIGNAGE

B. Signage font shall be at a maximum height for the following:

1. Food Court:
 - a. 12" high maximum for cut out letters lighted or not lighted.
 - b. Backlit box signage shall be at a maximum of 12" high, width shall not exceed mesh background space.
2. Signage weight shall not exceed as specified in 2.1.
3. No fluorescent lamp shall be used as signage lighting except for box signage.
4. No red color shall be used.
5. Two power outlets shall be provided per unit space.

PART 3 - EXECUTION

3.1 INSPECTION

A. Examine the areas and conditions where miscellaneous specialties are to be installed and notify Architect of conditions detrimental to the proper completion of work.

3.2 INSTALLATION

- A. Field verify dimensions prior to commencing work.
- B. Install signage and background including accessories, trim, anchorages, and modifications in accordance with manufacturer's written instructions and recommendations for a complete installation.
- C. Install signage and background as neatly and securely as indicated.
- D. Fastening shall be inconspicuous and concealed where possible.